

Varmepumpe Starter 2011

Dato	Januar	Februar	Marts	April	Maj	Juni	Juli	August	September	Oktober	November	December	Sum
1				12	21	13	16	12	15	15	20	6	130
2				23	17	20	18	13	17	18	13	10	149
3				19	14	17	23	17	19	16	17	8	150
4			5	14	20	19	18	16	22	11	16	10	151
5			15	14	20	17	21	14	14	18	28	8	169
6			13	10	18	15	15	15	17	14	18	10	145
7			10	15	16	14	13	15	13	20	11	13	140
8			10	12	20	22	15	12	16	18	14	6	145
9			6	25	13	15	19	22	17	20	10	9	156
10			3	21	16	26	13	14	15	12	14	6	140
11			12	16	19	17	19	14	13	17	12	11	150
12			12	17	16	16	11	19	16	18	10	6	141
13			17	14	18	17	17	16	13	14	16	12	154
14			14	17	15	18	15	17	17	16	13	4	146
15			6	14	23	14	16	16	17	20	13	7	146
16			10	23	15	16	26	14	16	20	6	5	151
17			3	20	17	19	19	17	21	22	4	14	156
18			9	25	16	15	20	16	19	22	5	14	161
19			10	20	20	26	18	14	15	18	7	6	154
20			13	23	26	17	15	12	13	6	6	5	136
21			10	19	17	20	11	10	19	6	9	2	123
22			15	18	22	23	11	13	13	8	11		134
23			17	15	22	19	14	13	13	19	9		141
24			16	16	18	20	17	10	20	15	14		146
25			12	28	18	20	14	15	19	12	10		148
26			11	15	17	15	16	9	13	15	11		122
27			11	18	16	20	14	16	15	16	11		137
28			16	13	18	12	10	19	17	18	8		131
29			18	17	23	18	10	18	15	14	12		145
30			10	17	13	13	11	13	19	20	8		124
31			14		20		10	16		19			79
I alt			318	530	564	533	485	457	488	497	356	172	4.400
pr. dag			11	18	18	18	16	15	16	16	12	8	15
Kwh			653	316	200	148	134	117	164	376	602	561	3.271
pr. start			2,05	0,60	0,35	0,28	0,28	0,26	0,34	0,76	1,69	3,26	0,74