

**Varmepumpe Starter
2011**

Dato	Januar	Februar	Marts	April	Maj	Juni	Juli	August	September	Oktober	November	December	Sum	Middel
1				12	21	13	16	12	15	15	20	6	130	14
2				23	17	20	18	13	17	18	13	10	149	17
3				19	14	17	23	17	19	16	17	8	150	17
4			5	14	20	19	18	16	22	11	16	10	151	15
5			15	14	20	17	21	14	14	18	28	8	169	17
6			13	10	18	15	15	15	17	14	18	10	145	15
7			10	15	16	14	13	15	13	20	11	13	140	14
8			10	12	20	22	15	12	16	18	14	6	145	15
9			6	25	13	15	19	22	17	20	10	9	156	16
10			3	21	16	26	13	14	15	12	14	6	140	14
11			12	16	19	17	19	14	13	17	12	11	150	15
12			12	17	16	16	11	19	16	18	10	6	141	14
13			17	14	18	17	17	16	13	14	16	12	154	15
14			14	17	15	18	15	17	17	16	13	4	146	15
15			6	14	23	14	16	16	17	20	13	7	146	15
16			10	23	15	16	26	14	16	20	6	5	151	15
17			3	20	17	19	19	17	21	22	4	14	156	16
18			9	25	16	15	20	16	19	22	5	14	161	16
19			10	20	20	26	18	14	15	18	7	6	154	15
20			13	23	26	17	15	12	13	6	6	5	136	14
21			10	19	17	20	11	10	19	6	9	3	124	12
22			15	18	22	23	11	13	13	8	11	9	143	14
23			17	15	22	19	14	13	13	19	9	9	150	15
24			16	16	18	20	17	10	20	15	14	8	154	15
25			12	28	18	20	14	15	19	12	10	13	161	16
26			11	15	17	15	16	9	13	15	11	12	134	13
27			11	18	16	20	14	16	15	16	11	14	151	15
28			16	13	18	12	10	19	17	18	8	7	138	14
29			18	17	23	18	10	18	15	14	12	8	153	15
30			10	17	13	13	11	13	19	20	8	8	132	13
31			14		20		10	16		19		3	82	14
I alt			318	530	564	533	485	457	488	497	356	264	4.492	449
pr. dag			11	18	18	18	16	15	16	16	12	9	15	15
Kwh			653	316	200	148	134	117	164	376	602	850	3.560	356
pr. start			2,05	0,60	0,35	0,28	0,28	0,26	0,34	0,76	1,69	3,22	0,79	0,98
Varme			1.269	352	60	4	7	6	107	722	1.449	3.834	7.810	781
Vand			285	305	295	285	257	213	209	261	247	306	2.663	266
I alt kwh			1.554	657	355	289	264	219	316	983	1.696	4.140	10.473	1.047
Varmt vand			10.264	10.548	10.507	9.883	9.138	8.200	7.358	11.598	10.925	9.477	97.898	9.790
COP			2,38	2,08	1,78	1,95	1,97	1,87	1,93	2,61	2,82	4,87	2,43	2,43

**Varmepumpe Starter
2012**

Dato	Januar	Februar	Marts	April	Maj	Juni	Juli	August	September	Oktober	November	December	Sum	Middel
1	8	3	5	15	9	15	17	8	14	11	7	4	116	10
2	9	3	4	7	11	16	10	7	17	7	6	3	100	8
3	3	5	10	3	12	17	19	8	11	8	7	4	107	9
4	7	1	8	8	8	9	9	9	16	10	9	7	101	8
5	6	2	7	10	4	11	14	17	9	11	5	5	101	8
6	2	1	4	14	5	9	10	12	16	8	2	3	86	7
7	5	3	12	7	11	13	16	13	8	9	6	5	108	9
8	8	1	9	13	13	15	12	13	8	5	7	2	106	9
9	8	6	10	9	12	19	10	10	7	10	5	6	112	9
10	7	1	17	4	14	13	9	12	5	7	9	3	101	8
11	7	5	5	8	14	15	13	13	7	5	12	1	105	9
12	8	8	6	6	16	11	9	17	5	9	11	3	109	9
13	3	3	10	13	18	10	21	12	6	6	6	3	111	9
14	9	3	8	15	11	11	9	10	2	9	8	2	97	8
15	9	8	7	21	13	14	12	12	4	10	7	4	121	10
16	7	1	11	10	17	17	13	11	8	10	7	4	116	10
17	10	4	16	8	19	16	10	9	6	10	8	4	120	10
18	6	8	13	14	18	8	14	14	13	8	9	4	129	11
19	5	3	12	14	13	12	4	9	17	7	7	2	105	9
20	6	10	7	15	14	14	9	10	14	8	10	3	120	10
21	3	5	10	10	17	9	7	8	12	10	9	5	105	9
22	7	4	12	18	12	13	9	12	13	8	7	3	118	10
23	10	11	13	13	15	12	18	9	15	8	6	4	134	11
24	1	9	14	8	7	21	8	10	11	10	6	6	111	9
25	3	9	16	14	11	13	20	9	8	8	7	8	126	11
26	5	13	14	14	18	10	14	14	12	7	6	8	135	11
27	1	6	8	12	12	13	19	10	12	10	7	4	114	10
28	7	5	15	17	15	9	7	10	15	7	8	5	120	10
29	1	3	14	23	8	9	10	11	9	6	4	6	104	9
30	2		12	13	10	13	6	11	15	8	5	6	101	9
31	3		13		7		8	10		8		5	54	8
I alt	176	144	322	356	384	387	366	340	315	258	213	132	3.393	283
pr. dag	6	5	10	12	12	13	12	11	11	8	7	4	9	9
Kwh	902	977	554	400	146	122	104	88	166	380	587	971	5.397	450
pr. start	5,13	6,78	1,72	1,12	0,38	0,32	0,28	0,26	0,53	1,47	2,76	7,36	1,59	2,34
Varme	2.970	3.205	1.636	1.165	192	4	0	0	383	1.283	2.085	3.175	16.098	1.342
Vand	220	191	248	212	189	244	226	182	208	235	228	280	2.663	222
I alt kwh	3.190	3.396	1.884	1.377	381	248	226	182	591	1.518	2.313	3.455	18.761	1.563
Varmt vand	6.577	4.900	6.623	5.702	5.403	7.005	6.319	5.529	6.784	6.708	6.692	7.630	75.872	6.323
COP	3,54	3,48	3,40	3,44	2,61	2,03	2,17	2,07	3,56	3,99	3,94	3,56	3,15	3,15

**Varmepumpe Starter
2013**

Dato	Januar	Februar	Marts	April	Maj	Juni	Juli	August	September	Oktober	November	December	Sum	Middel
1	10	5	13	10									38	10
2	6	5	7	16									34	9
3	10	3	6	14									33	8
4	7	4	14	10									35	9
5	12	4	9	9									34	9
6	12	3	11	10									36	9
7	12	5	9	10									36	9
8	5	2	3	9									19	5
9	5	4	6	14									29	7
10	5	4	1	6									16	4
11	4	1	7	11									23	6
12	3	4	5	6									18	5
13	3	2	9	12									26	7
14	5	7	9	12									33	8
15	2	3	6	9									20	5
16	1	4	5	9									19	5
17	4	2	9	14									29	7
18	1	5	0	15									21	5
19	3	2	5	15									25	6
20	4	4	5	10									23	6
21	2	7	5	13									27	7
22	2	4	6	12									24	6
23	4	2	6	11									23	6
24	4	6	12										22	7
25	1	4	9										14	5
26	4	5	8										17	6
27	5	6	15										26	9
28	6	2	13										21	7
29	5		1										6	3
30	4		10										14	7
31	2		9										11	6
I alt	153	109	233	257									752	188
pr. dag	5	4	8	11									7	7
Kwh	965	924	923										2.812	937
pr. start	6,31	8,48	3,96										3,74	6,25
Varme	3.134	2.895	2.808										8.837	2.946
Vand	250	226	255										731	244
I alt kwh	3.384	3.121	3.063										9.568	3.189
Varmt vand	7.252	6.338	7.076										20.666	6.889
COP	3,51	3,38	3,32										3,40	3,40